



GOVERNMENT OF KERALA

Abstract

Public Works Department -GENERAL-Budget Work 2024-25 - (20% Provision)- Upgradation work-Providing BM and BC to Ramankulangara-Kochu Maruthadi temple road-in Chavara LAC - Administrative Sanction – Accorded - Orders issued.

PUBLIC WORKS (G) DEPARTMENT

G.O.(Rt)No.304/2025/PWD Dated,Thiruvananthapuram, 28-02-2025

Read Letter No.CEPWD/9809/2024-DB1(PL)-RD dated 08.08.2024 from the Chief Engineer (Roads), Public Works Department, Thiruvananthapuram.

ORDER

The Chief Engineer (Roads) as per the letter read above, has submitted detailed estimate in respect of the work "GENERAL-Budget Work 2024-25 - (20% Provision)- Upgradation work-Providing BM and BC to Ramankulangara-Kochu Maruthadi temple road-in Chavara LAC" , at an estimate cost of Rs. 197 Lakh and requested government to accord Administrative Sanction for the work under the head of Account 5054- 04-337-97-ODR.

2. Government have examined the matter in detail and are pleased to accord Administrative Sanction for work "GENERAL-Budget Work 2024-25 - (20% Provision)- Upgradation work-Providing BM and BC to Ramankulangara-Kochu Maruthadi temple road-in Chavara LAC" for an amount of Rs. 197 Lakh (Rupees One Hundred and Ninety Seven Lakh only) by debiting the expenditure from the Head of Account 5054-04-337-97-ODR, subject to the following conditions;

1. The TS authority shall ensure the admissibility of provisions included in the estimate with the site conditions before issuing the Technical Sanction.
2. The CE shall ensure that the works proposed in the estimate shall satisfy the functional requirements as envisaged.

3. The TS authority shall review the higher coefficient adopted for working out the quantity of Steel for drainage works.
4. The Structural provisions given for the drain shall be ensured by the TS authority before according TS and shall meet the requirements as per IRC.
5. The working chainages shall be ensured by the TS authority.
6. The TS authority shall review the necessity of providing BM & BC and explore the possibility of 20 mm Open / Close Graded Premix Surfacing (OGPS/CGPS) by considering the traffic intensity and economy.

(By order of the Governor)
A MUMTHAS BEEGOM
ADDITIONAL SECRETARY

To:

The Chief Engineer, Roads, Public Works
Department, Thiruvananthapuram.

The Superintending Engineer (Roads), South Circle, Public Works
Department, Thiruvananthapuram

The Executive Engineer, Roads, Public Works Department, Kollam

The Accountant General, (A&E/Audit), Kerala, Thiruvananthapuram.

The Finance Department (No. I&PW-B1/336/2024-FIN (E 2980455)
dated 17.02.2025)

Stock File/Website.

Forwarded /By order

Section Officer