



GOVERNMENT OF KERALA

Abstract

Public Works Department - Construction of New Building for Kunnicothu Police Station in Pathanapuram LAC- Administrative Sanction accorded - Orders issued.

PUBLIC WORKS (E) DEPARTMENT

G.O.(Rt)No.240/2026/PWD Dated,Thiruvananthapuram, 20-02-2026

Read 1 Letter No.CEPWD-GEN/34/2025-A4(W)-BL dated 23.08.2025 from Chief Engineer, (Buildings), Public Works Department.

2 AS No.AS/PWD/25/48975.

ORDER

The Chief Engineer (Buildings), Public Works Department, Thiruvananthapuram has submitted a proposal as per the letter read above seeking Administrative Sanction for the "Construction of New Building for Kunnicothu Police Station in Pathanapuram LAC" with a detailed estimate for an amount of ₹140.00 lakhs under the Head of Account "4059-01-051-89-16-00(P-V) based on DSR 2018 and 18% GST.

2. Government have examined the matter in detail and are pleased to accord Administrative Sanction for the 20 % provision work "Construction of New Building for Kunnicothu Police Station in Pathanapuram LAC" for an amount of ₹140.00 lakh (Rupees One hundred and forty lakh only) under the Head of Account "4059-01-051-

89(Police)-00- 16-00(P-V) subject to the following conditions:

- a. The Chief Engineer (Buildings) shall ensure that the works proposed in the estimate shall satisfy the functional requirements as envisaged.
- b. The foundation provisions in the estimate for the construction of building shall be verified by TS authority before issuing the Technical Sanction and if required, the detailed soil investigation shall be done through Government approved agencies having good expertise in this area.
- c. Structural Design is not seen done for the proposed building construction. Hence, TS authority shall ensure the structural adequacy and structural stability before issuing the Technical Sanction considering economy.
- d. Lump sum quantity is provided for reinforcement items for RCC work. Hence, quantity shall be arrived based on the design drawings before according TS.
- e. Lump sum provision is provided for electrification works for an amount of ₹7.50 lakhs. Hence, detailed estimate shall be prepared before issuing Technical Sanction.
- f. TS authority shall ensure the correctness of the rates adopted for observed data provided in the estimates and the quality of materials during the time of execution.
- g. The competent authority shall ensure the admissibility of provisions included in the estimate with the site conditions before issuing the Technical Sanction.

(By order of the Governor)

K BIJU I A S
SECRETARY

To:

The Chief Engineer (Buildings), Public Works Department,
Thiruvananthapuram

The Executive Engineer, PWD Buildings Division, Kollam.

The Principal Accountant General(Audit/A&E), Kerala,
Thiruvananthapuram

The Finance Department (Vide U.O.No.3315494/I&PW-B1/274/2025-
FIN dated 18.11.2025 and 20.01.2026)

✓The Information Officer (Web & New Media)

Stock File/Office Copy

Forwarded /By order

Signed by

Sudha B Section Officer

Date: 20-02-2026 16:28:51

Copy to :

The Private Secretary to the Minister for Public Works

P.A. to the Secretary, Public Works Department

P.A. to the Additional Secretary, Public Works Department